

SINGAPORE STANDARD

SS 525 : 2006

(ICS 91.060.20; 91.140.80)

CODE OF PRACTICE FOR

Drainage of roofs

(Incorporating Amendment No.1, September 2007)

(Formerly CP 26 : 1983)

Published by
SPRING Singapore
2 Bukit Merah Central
Singapore 159835
SPRING Singapore Website: www.spring.gov.sg
Standards Website: www.standards.org.sg



SPRING
singapore
Enabling Enterprise

SINGAPORE STANDARD
SS 525 : 2006
(ICS 91.060.20; 91.140.80)

CODE OF PRACTICE FOR
Drainage of roofs

(Incorporating Amendment No.1, September 2007)

(Formerly CP 26 : 1983)

All rights reserved. Unless otherwise specified, no part of this Singapore Standard may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from SPRING Singapore at the address below:

Head
Standardisation Department
SPRING Singapore
2 Bukit Merah Central
Singapore 159835
Telephone: 62786666 Telefax: 62786667
Email: stn@spring.gov.sg

ISBN 981-4154-35-0

Contents

	Page
Foreword _____	10
 CLAUSES	
<hr/> <hr/>	
Section One – General	
1 Scope _____	11
2 References _____	11
3 Definitions _____	12
 Section Two – Materials and components	
4 Materials and components for rainwater goods _____	12
4.1 General _____	12
4.2 Gutter components _____	12
4.2.1 Aluminium _____	12
4.2.2 Titanium zinc _____	12
4.2.3 Stainless steel SS316-2B finish _____	12
4.2.4 Zinc/aluminium alloy coated steel _____	12
4.2.5 Copper-natural mill finish & pre-weathered copper _____	13
4.2.6 GRP (Glass Reinforced Plastics) _____	13
4.3 Downpipes _____	13
4.3.1 Cast Iron _____	13
4.3.2 Unplasticised PVC _____	13
4.3.3 Titanium zinc _____	13
4.3.4 Stainless steel SS316–2B finish _____	13
4.3.5 Zinc/aluminium alloy coated steel _____	13
4.3.6 Polyethylene (PE) _____	13
4.4 New materials _____	13
 Section Three – Design	
5 Meteorological aspects of design _____	13
5.1 General _____	13
5.2 Design rates of rainfall _____	14
5.3 Wind _____	15
5.4 Thermal movement _____	15
5.4.1 Gutters _____	15
5.4.2 Rainwater pipes _____	15
6 Run-off _____	16
6.1 Effective catchment area _____	16

	Page
6.1.1 General _____	16
6.1.2 Flat roofs _____	16
6.1.3 Sloping and curved roofs _____	16
6.1.4 Vertical surfaces _____	16
6.2 Rate Of run-off _____	17
7 Hydraulic design of roof drainage _____	17
7.1 General principles _____	17
7.2 Standard method of design _____	17
7.3 Gutters _____	17
7.3.1 Gutter provision _____	17
7.3.2 Leaf cover for gutters _____	18
7.3.3 Minimum gradient _____	18
7.3.4 Type of gutters _____	18
7.3.5 Profile of gutters _____	18
7.3.6 Dimensions of gutters _____	18
7.4 Roof drainage design flowchart _____	19
 Section Four – Work on site	
8 Types and spacing of fixings _____	35
8.1 Gutters – general considerations _____	35
8.1.1 Gutter support _____	35
8.1.2 Deep gutters _____	35
8.1.3 Eaves gutters _____	35
8.1.4 Moulded gutters _____	36
8.1.5 Industrial eaves gutters _____	36
8.1.6 Valley, skylight, parapet, boundary wall and large box gutters _____	36
8.2 Rainwater pipes _____	36
8.2.1 Pipes which require painting _____	36
8.2.2 Pipe fixing _____	36
8.2.3 Materials for pipe fixing _____	36
9 Jointing _____	36
9.1 Jointing gutters _____	36
9.1.1 General _____	36
9.1.2 Cast iron and steel gutters _____	37
9.1.3 Aluminium gutters _____	37
9.2 Jointing rainwater pipes _____	37
9.2.1 General _____	37
9.2.2 Horizontal runs of pipes _____	37

	Page
9.2.3 Flat roofs _____	37
9.2.4 Metal pipes _____	37
9.2.5 uPVC pipes _____	38
10 Access to pipes _____	38
11 Encased pipes _____	38
12 Termination of rainwater pipes _____	38
13 Internal rainwater pipes _____	38

Section Five – Testing, commissioning and maintenance procedures for gravity and siphonic roof drainage systems

14 Testing and commissioning _____	38
14.1 General _____	38
14.2 Gutters and flat roofs _____	39
14.2.1 Test for leakage _____	39
14.2.2 Visual inspection _____	39
14.2.3 Inspection for ponding _____	39
14.3 Rainwater pipeworks _____	39
14.3.1 Test for leakage _____	39
14.3.2 Visual inspection _____	39
14.3.3 Test for blockage _____	39
15 Maintenance _____	39
15.1 Periodic inspection and cleaning _____	39

Section Six – Prevention of mosquito breeding in roof drainage system

16 General _____	40
17 Roof drainage _____	40
17.1 Roof gutters _____	40
17.2 Leaf covers for roof gutters _____	40
17.3 Rainwater downpipes for roof drainage _____	40

ANNEXES

A Symbols _____	68
B Bibliography _____	70

TABLES

1	Flow capacity of standard eaves gutters (level) _____	60
2	Reduction factors for capacities of long half-round eaves gutters _____	60
3	Reduction factors for capacities of standard eaves gutters containing angles _____	60
4	Capacity of outlet weirs for flat roofs _____	61
5	Capacity of overflow weirs (sharp-edged weir) _____	61
6	Capacity of overflow spout pipes _____	62
7(a)	Capacity of grated circular outlets _____	63
7(b)	Capacity of grated circular outlets (90 % opening) _____	64
7(c)	Capacity of grated circular outlets (80 % opening) _____	64
7(d)	Capacity of grated circular outlets (70 % opening) _____	65
7(e)	Capacity of grated circular outlets (60 % opening) _____	65
8	Capacity of vertical rainwater pipes _____	66
9	Capacity of horizontal rainwater pipes _____	67

FIGURES

1	Design intensity of 5-minute storm in Singapore _____	41
2	Calculation of effective catchment area A_e for roofs _____	42
3	Calculation of effective catchment area A_e for roof with vertical surfaces _____	43
4	Definition of eaves gutters _____	44
5	Definition of valley, parapet and boundary wall gutters _____	45
6	Description of flat roof drainage _____	46
7	Profile of gutters _____	46
8	Dimensions of gutters _____	47
9	Dimensions of eaves gutter (half-round and nominally half-round) _____	48
10	Dimensions of eaves gutter (other profiles) _____	49
11	Dimensions of valley, parapet and boundary wall gutters _____	50
12	Dimensions of gutters with restricted discharge _____	51
13	Flow capacities of freely-discharging half-round gutters _____	52
14	Design chart for freely-discharging trapezoidal gutters _____	53
15	Capacity of freely-discharging gutters _____	54
16	Capacity of circular outlets (without grating) _____	55
17	Effect of resistance in level gutters _____	56
18	Design chart for trapezoidal gutters with restricted discharge _____	57
19	Roof eaves design (without gutters) _____	58
20	Leaf cover details _____	59

FLOWCHARTS

1	Selection of design rainfall intensity (mm/hr) _____	20
2	Calculation of run-off _____	22
3a	Eaves gutters; half-round and nominally half-round (freely discharged gutter)_____	23
3b	Eaves gutters: other profiles (freely discharged gutter) _____	25
3c	Valley, parapet and boundary wall gutters (freely discharged gutter)_____	27
3d	Gutter with restricted discharge _____	30
3e	Flat roof drainage _____	32
4	Vertical and horizontal pipe (gravity system) _____	33
5	Siphonic roof drainage system _____	34

Foreword

This Singapore Standard is prepared by the Technical Committee on Architectural Works under the purview of the Building and Construction Standards Committee.

For prevention of mosquito breeding, roof gutters are not allowed for all new developments effective 1 November 2005 except for those where waiver has been obtained from the National Environment Agency (NEA) in writing. In such cases the design of roof gutters shall comply with the requirements as stipulated in this standard.

Additional guidelines for prevention of mosquito breeding have been incorporated to recognise the public health risk posed by roof drainage system and to take the necessary steps at the design stage to address the risk.

Factors relevant to the sizing of roof drainage channels under local rainstorm conditions and a method for direct design are included. Equations developed empirically overseas are adopted and specific systems for low and high-rise buildings were considered.

This standard is intended to serve as a guide for architects, engineers, builders and others responsible for the design of drainage systems conveying rainwater from roofs to the point of discharge into the surface drain.

This standard will be referred to in the National Productivity Quality Specification (NPQS) for the preparation of building projects specifications.

In revising this standard, the latest British Standard Gravity Drainage Systems Inside Buildings – Part 3 : Roof drainage, layout and calculation (BS EN 12056-3:2000) was used as reference.

Acknowledgement is made for the use of information from the above reference and the valuable contributions offered by the Meteorological Services Division, NEA.

Attention is drawn to the possibility that some of the elements of this Singapore Standard may be the subject of patent rights. SPRING Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

1. *Singapore Standards are subject to periodic review to keep abreast of technological changes and new technical developments. The changes in Singapore Standards are documented through the issue of either amendments or revisions.*
2. *Compliance with a Singapore Standard does not exempt users from legal obligations.*

Code of practice for drainage of roofs

Section One – General

1 Scope

This code specifies requirements for the drainage of surface water from roofs and walls and recommends methods of designing gutters, gutter outlets and rainwater downpipes (see Section Three).

Performance requirements for siphonic roof drainage systems are also outlined.

The code also gives guidance as to the choice of materials (see Section Two) in connection with fixing and jointing the drainage systems (see Section Four). Section Five deals with inspection, testing and maintenance. Section Six covers guidelines for design of gutters for the prevention of mosquito breeding.

2 Normative references

The following referenced documents are indispensable for the application of this standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS EN 1462 : 1997	Brackets for eaves gutters. Requirements and testing
BS EN 988 : 1997	Zinc and zinc alloys. Specification for rolled flat products for building
BS EN 10088 :-	Stainless steels Part 1 : 1995 List of stainless steels Part 2 : 1995 Technical delivery conditions for sheet/plate and strip for general purposes Part 3 1995 Technical delivery conditions for semi-finished products, bars, rods and sections for general purposes
BS EN 13598 :-	Plastics piping systems for non-pressure underground drainage and sewerage. Unplasticised poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) Part 1 : 2003 Specifications for ancillary fittings including shallow inspection chambers
BS EN 612 : 1996	Eaves gutters and rainwater down-pipes of metal sheet. Definitions, classifications and requirements
BS 460 : 2002	Cast iron rainwater goods. Specification
BS 6100 :-	Glossary of building and civil engineering terms Part 1 : Section 1.3 : Subsection 1.3.2 : 1989 General and miscellaneous. Parts of construction works. Roofs and roofing Part 2 : Section 2.7 : 1992 Civil engineering. Public health. Environmental engineering Part 3 : Section 3.3 : 1992 Services. Sanitation
BS 5168 : 1975	Glossary of rheological terms
SS 213 : 1998	Unplasticised PVC pipes and fittings for soil, waste and vent. Applications