

Singapore Standard SS 608 : 2015

Code of practice for gas installation

AMENDMENT NO. 1

November 2017

1. Page 27, 9.3 Gas appliances and flues

(a) *Insert a new requirement after (b) as follows:*

(c) Flexible tubings used in flexible connections shall comply with BS 669-1 and hang freely in a curved position without any twisting, torsion or strain.

(b) *Renumber items (c) to (e) accordingly.*