

**CODE OF PRACTICE FOR MECHANICAL VENTILATION AND
AIR-CONDITIONING IN BUILDINGS**

AMENDMENT NO.1

February 2000

1. **Page 15, Table 2**

- (a) Under 'Type of building/Occupancy', *replace* 'lobbies' with 'lobbies***'
- (b) *Add* the following note after the table:

*** Lobbies of area of 10m² or less are exempted from being mechanically ventilated.

2. **Page 27, Clause 7.1.3**

Delete ' , not lower than the design value' at the end of this subclause.

3. **Page 32, Clause 7.11.6(a)**

Replace 'should not be designed' with 'should be designed'.