

**CODE OF PRACTICE FOR MECHANICAL VENTILATION
AND AIR-CONDITIONING IN BUILDINGS**

ERRATUM NO. 1

June 2001

1. **Page 47, Subclause 13.10 (c)**

Replace the text of item (c) with the following sentence:

Cooling tower has to be cleaned and treated every month following the 'Code of practice for the control of legionella bacteria in air conditioning cooling towers', published by the Ministry of the Environment.

2. **Page 53, Publications referred to**

Insert the following title after the last reference 'SMACNA 1995 HVAC duct...' :

Code of practice for the control of legionella bacteria in air conditioning cooling towers