

Singapore Standard SS 2 : Part 2: 1999

**SPECIFICATION FOR STEEL FOR THE REINFORCEMENT OF CONCRETE
PART 2 : RIBBED BARS (STEEL GRADE 500)**

ERRATUM NO. 1

October 2000

Page 9, Table 1

Replace the nominal cross-sectional area of '78.3 mm²' for 10 mm nominal bar diameter with '78.5 mm²'.