

**SPECIFICATION FOR CABLE TRUNKING
MADE OF INSULATING MATERIAL**

ERRATUM NO. 1

May 2000

1. **Page 12, Table 2**

Replace 'Kg' and 'Mm' by 'kg' and 'mm', respectively.

2. **Page 14, Subclause 11.1.2**

Replace the first paragraph 'The test is performedtemperature of 650°C' by the following text:

The test is performed according to clauses 4 to 10, of IEC 60695-2-1 under the following conditions:

- for parts of insulating material necessary to retain current-carrying parts in position, by the test made at a temperature of 850°C;
- for parts of insulating material not necessary to retain current-carrying parts in position, even though they are in contact with them, and for parts of insulating material retaining earthing terminals in position, by the test made at a temperature of 650°C.