

SPECIFICATION FOR CABLE TRUNKING MADE OF INSULATING MATERIAL

AMENDMENT NO. 1

February 2001


1. **Page 12, Subclause 9.4 Linear deflection test**
 - a) *Delete* the text from subclauses 9.4.1 to 9.4.5.
 - b) *Insert* 'Test is under consideration' after '9.4.1'.
2. **Page 13, Subclause 11.1.1 Flame test**

Replace '600 mm' by '675 mm'.
3. **Page 17, Figure 1 – Cable supporting test apparatus**

Replace with the attached Figure 1.
4. **Page 18, Figure 2 – Impact test apparatus**


Replace with the attached Figure 2.
5. **Page 20, Figure 4 – Arrangement for flame test**

Replace 'Pince' by 'Clamp'



Dimensions in mm

Figure 1 – Cable supporting test apparatus



Dimensions in mm

Figure 2 – Impact test apparatus