

Singapore Standard CP 47 : 1989

**CODE OF PRACTICE FOR TEMPORARY ELECTRICAL
INSTALLATIONS FOR SHIPBUILDING AND SHIPREPAIRING YARDS**

AMENDMENT NO. 1

November 1990

1. **Page 10, Subclause 3.2.8**

Amend the subclause as follows:

"Flexible cords of portable hand-lamps shall be of the circular type having screened Type EM2 rubber sheath or of PVC insulated PVC sheathed type complying with SS 236."

2. **Page 10, Subclause 3.2.17**

Add the following at the end of the first sentence:

"unless the cables are so protected as to prevent mechanical damage."

3. **Page 12, Subclause 3.3.11 – Light fixtures**

Add the following at the end of the second paragraph:

"For areas where low angle light is required, the light fitting shall be properly mounted."