

Singapore Standard 167 : 1977

**SPECIFICATION FOR GENERAL PURPOSE FUSE LINKS FOR
DOMESTIC AND SIMILAR PURPOSES (PRIMARYLY FOR USE IN PLUGS)**

AMENDMENT NO. 1

September 1995

1. Page 4, Contents

Delete the title 'Type Tests' against Subclause 8.1 and *substitute* 'General'.

2. Page 5, Foreword

(a) *Insert* the following two paragraphs after the second paragraph:

'Fuses within the scope of this standard are not sensitive to normal electromagnetic disturbance generated and therefore no immunity tests are required.

Significant electromagnetic disturbance generated by a fuse is limited to the instant of its operation. Provided that the maximum arc voltages during operation in the type test comply with the requirements of the clause in this standard specifying maximum arc voltage, the requirements for electromagnetic compatibility are deemed to be satisfied.'

(b) *Delete* 'SS 145 : 1976 - 13A Plugs, Switched Socket-Outlets and Boxes' and *substitute* 'SS 145 : 1985 - 13A Plugs, Switched and Unswitched Socket Outlets'

3. Page 10, Subclause 7.3

Delete '27 ± 2°C' and *substitute* '27 ± 5°C'.

4. Page 12, Subclause 8.1 Type Tests

(a) *Delete* the title and *substitute* '8.1 General'.

(b) *Insert* the following sentence at the beginning of the subclause:

'The requirements specified in Subclauses 5.5, 5.6 and 5.7 shall be verified in accordance with Subclauses 8.2, 8.3 and 8.4 respectively.'