

**CODE OF PRACTICE FOR THE INSTALLATION AND MAINTENANCE OF  
EMERGENCY LIGHTING AND POWER SUPPLY SYSTEMS IN BUILDINGS**

**AMENDMENT NO. 1**

May 2003

**1. Page 20, 5.2.3 Prevention of over-discharge**

*Replace text of (b) by :*

(b) before the battery voltage reaches 85% of the nominal system voltage.

**2. Page 21, 5.2.6 Unearthed supply system**

*Insert after the paragraph :*

NOTE. This clause is not applicable to UPS systems. The UPS system (where used) shall comply with 6.6.27 of IEC 62040-3 : 1999 for earth fault test if intermediate d.c. circuit and/or battery circuit is isolated from earth.

**3. Page 55, Publications referred to in this standard**

*Add :*

IEC 62040-3    Uninterruptible power systems (UPS)  
Part 3 : 1999    Method of specifying the performance and test requirements