

Singapore Standard CP 48 : 2005

CODE OF PRACTICE FOR WATER SERVICES

AMENDMENT NO. 1

October 2006

1. Page 27, Subclause 5.1.1

Add the following sentence just before the sentence “All burrs shall be removed from the ends.....”:

Lead based solders shall not be used in potable water services.