

CODE OF PRACTICE FOR DRAINAGE OF ROOFS

AMENDMENT NO. 1

September 2007

1. Page 34, 5.2 and 5.3

Replace the text of 5.2 and 5.3 as follows:

5.2 Test reports on the coefficient of hydraulic loss and its water depth in relation to flow rate of the siphonic roof outlets shall be obtained from accredited bodies or laboratories.

5.3 Test reports on the software used for hydraulic calculation in siphonic systems shall be obtained from accredited bodies or laboratories.