

Singapore Standard CP 48 : 2005

Code of practice for water services

AMENDMENT NO. 3

May 2013

1. Page 21, 3.2 Storage capacity, new subclause 3.2.4

Insert the following new subclause:

3.2.4 The effective capacities of the storage tanks shall be clearly and visibly marked on the sides of the tanks.

2. Page 31, 5.6.4

Replace the subclause with the following:

An isolating stopvalve (without handles) shall be installed adjacent to the meter.