

**Code of practice for the storage of flammable liquids**

**CORRIGENDUM NO. 1**

May 2016

**1. Page 23, 4.2.6 Sprinkler protected area**

*Replace* 1<sup>st</sup> paragraph, 2<sup>nd</sup> sentence with “The 10 m separation distance can be reduced to 5 m if all fire safety cabinets have at least a 30-minute fire rating.”

**2. Page 25, Figure 4 (b) Fire safety cabinet within a sprinkler protected factory building**

*Replace* the boxed text on fire rating with:

<p><u>Min. 10m</u> separation if cabinet is listed for <u>10 minutes</u> fire rating <u>Min. 05m</u> separation if cabinet is listed for <u>30 minutes</u> fire rating</p>
--

**3. Page 77, 10.5 Fire pumps**

(a) *Replace* “fire pump” and “firewater pump” with “fire water pump”.

(b) *Replace* “firewater” with “fire water”.