

**Code of practice for the design, installation and maintenance of emergency  
lighting and power supply systems in buildings  
– Part 1 : Emergency lighting**

**AMENDMENT NO. 1**

November 2017

**1. Page 6, National Foreword**

(a) *Replace* “SS 263-2” under “Normative reference” with “SS IEC 60598-2-22”.

(b) *Delete* “delete last paragraph” under “Escape lighting”.

**2. Page 10, Clause 3 Normative references**

*Delete* “ISO 6309 Fire protection – Safety signs”.

**3. Page 12, 4.9 Safety sign**

*Delete* “ISO 6309”.

**4. Page 12, 4.10 Externally illuminated safety sign**

*Delete* the entire clause.

**5. Page 12, Clause 5 Emergency escape lighting**

*Reinstate* the requirement “Positions denoted as b, c, h, and i, if not on the escape route nor in an open area shall be illuminated to 5 lx minimum at the floor”.