

SINGAPORE STANDARD

Specification for earthing and bonding clamps



Published by

Enterprise
Singapore

SS 322 : 2015

(ICS 21.060.70; 29.120.20)

SINGAPORE STANDARD

Specification for earthing and bonding clamps

All rights reserved. Unless otherwise specified, no part of this Singapore Standard may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from Enterprise Singapore. Request for permission can be sent to: standards@enterprisesg.gov.sg.

ISBN 978-981-4726-21-4

This Singapore Standard was approved by the Electrical and Electronic Standards Committee on behalf of the Singapore Standards Council on 4 December 2015.

First published, 1987

First revision, 2015

The Electrical and Electronic Standards Committee, appointed by the Standards Council, consists of the following members:

	Name	Capacity
Chairman	: Er. Peter Leong Weng Kwai	<i>Member, Standards Council</i>
Deputy Chairmen	: Mr Cheong Tak Leong	<i>SPRING Singapore</i>
	Er. Tan Hak Khoon	<i>Energy Market Authority</i>
Advisor	: Mr Renny Yeo Ah Kiang	<i>Individual Capacity</i>
Secretary	: Mr Jason Low	<i>SPRING Singapore</i>
Members	: Dr Chua Sze Wey	<i>Agency for Science, Technology and Research</i>
	Assoc Prof Gooi Hoay Beng	<i>Nanyang Technological University</i>
	Er. Hashim Bin Mansoor	<i>Building & Construction Authority</i>
	Assoc Prof Ko Chi Chung	<i>National University of Singapore</i>
	Mr Koh Liang Hock	<i>SP PowerGrid Ltd</i>
	Er. Lim Ah Hee	<i>Housing & Development Board</i>
	Er. Lim Say Leong	<i>Singapore Business Federation</i>
	Er. Ling Shiang Yun /	<i>Association of Consulting Engineers Singapore</i>
	Er. Kenneth Liu	
	Mr Ng Kin Ming	<i>Singapore Electrical Contractors and Licensed Electrical Workers Association</i>
	Er. Ong Ser Huan	<i>Institution of Engineers Singapore</i>
	Mr Sim Geok Seng	<i>SPRING Singapore</i>
	Mr Sim Wee Meng	<i>Land Transport Authority</i>
	Mr Tan Boon Chong	<i>Singapore Manufacturing Federation</i>
	Mr Christopher Tan Eng Kiong	<i>Singapore Civil Defence Force</i>
	Mr Alfred Tan Lai Seng	<i>Singapore Electrical Trades Association</i>
	Dr Timothy Michael Walsh	<i>Solar Energy Research Institute of Singapore</i>
	Mr Justin Wu	<i>National Environment Agency</i>
Co-opted Member	: Mr Chong Weng Hoe	<i>Individual Capacity</i>

The Technical Committee on Electrical & Electronic Products, appointed by the Electrical and Electronic Standards Committee and responsible for the preparation of this standard, consists of representatives from the following organisations:

	Name	Capacity
Chairman	: Er. Lim Say Leong	<i>Member, Electrical and Electronic Standards Committee</i>
Deputy Chairman	: Mr Sim Geok Seng	<i>SPRING Singapore</i>
Secretary	: Mr Jason Low	<i>SPRING Singapore</i>
Members	: Er. Thomas Cheang	<i>Association of Consulting Engineers Singapore</i>
	Mr Chia Soo Ping	<i>Singapore Polytechnic</i>
	Mr Choong Po Siong	<i>Housing & Development Board</i>
	Prof Er Meng Joo	<i>Institution of Engineers Singapore</i>
	Dr Lai Weng Hong	<i>Singapore Semiconductor Industry Association</i>
	Mr Eric Lim	<i>Singapore Electrical Trades Association</i>
	Mr Francis Lim	<i>Land Transport Authority</i>
	Er. Joseph Michael	<i>Individual Capacity</i>
	Mr Seow Zhi Wei	<i>Energy Market Authority</i>
	Dr Shan Yueyan	<i>A*STAR National Metrology Centre</i>
	Assoc Prof So Ping Lam	<i>Nanyang Technological University</i>
	Mr Tan Boon Chong	<i>Singapore Manufacturing Federation</i>
	Ms Tan Lay Hua	<i>SP Services Ltd</i>
	Er. Wang Hee Weng	<i>Singapore Electrical Contractors and Licensed Electrical Workers Association</i>

The Working Group on Plugs, Socket Outlets and Switches, appointed by the Technical Committee to assist in the preparation of this standard, comprises of the following experts who contribute in their *individual capacity*:

	Name
Convenor	: Mr Tan Boon Chong
Members	: Mr Goh Sheng Sze
	Er. Lim Choon Poh
	Mr Lim Han Chong
	Mr Vincent Loo
	Er. Joseph Michael
	Mr Ong Ah Keong
	Mr Phua Kim Suah
	Mr Kenneth Seow
	Mr Kriegsman Tan
	Mr Ting Chiong Seng
	Mr Wong Chee Kian

The experts of the Working Group are nominated/recommended by the following organisations:

ABB Industry Pte Ltd

Energy Market Authority

Hager Electro Systems Pte Ltd

Housing Development Board

Legrand (S) Pte Ltd

Marian Technologies Pte Ltd

MK Electric (S) Pte Ltd

Singapore Electrical Testing Services

Singapore Manufacturing Federation

SP Services Ltd

SPRING Singapore

TUV SUD PSB Pte Ltd

Contents

	Page
National Foreword _____	6

Clauses

1	Scope _____	8
2	Normative references _____	8
3	Terms and definitions _____	8
4	General _____	9
5	Construction _____	9
6	Material _____	12
7	Electrical characteristics _____	12
8	Non-slipping torque _____	13
9	Marking _____	13

Annexes

A	Tests for electrical impedance and temperature rise _____	14
B	Short-time withstand current test _____	16
C	Torque test _____	18
D	Examples of earthing and bonding clamps _____	20

Tables

1	Termination reference and conductor size _____	10
2	Maximum torques for screws _____	11
A.1	Test currents for temperature rise _____	15
B.1	Test currents for short-time withstand current _____	17
C.1	Non-slipping torque values _____	19

Figures

A.1	Test arrangement _____	15
B.1	Test arrangement _____	17
C.1	Apparatus for the torque test _____	18

National Foreword

This Singapore Standard was prepared by the Working Group on Plugs, Socket Outlets and Switches appointed by the Technical Committee for Electrical and Electronic Products under the direction of the Electrical and Electronic Standards Committee.

Earthing and bonding are essential to the safety of the wiring system as laid down in Singapore Standard, Code of Practice 5. The quality of the clamps used for these purposes is an important consideration.

This standard is a revision of SS 322 : 1987(2008). It is a modified adoption of the BS 951 : 2009 'Electrical earthing. Clamps for earthing and bonding. Specification', and is implemented with the permission of BSI Standards Limited.

The deviations are as follows:

<u>Clauses/Subclauses</u>	<u>Modification</u>
Foreword	<i>Replaced with National Foreword.</i>
Clause 3	<i>Added the definitions, 'bonding', 'protective conductor' and 'earthing conductor'.</i> <i>Explanation: The additional terms found in BS 951: 2009 are defined in SS 322 : 2015 for clarity.</i>
Clause 5.3 - NOTE	<i>Deleted the note, 'The terminal may be of a screwed or screwless construction'.</i> <i>Explanation: Terminals of a screwless construction are not permitted for use in Singapore.</i>
Clause 5.4 - Table 2	<i>Modified Table 2, 'Maximum torques for screws'.</i> <i>Explanation: The torque values listed in Table 2 are widely recognised and accepted by the industry in Singapore.</i>
Clause 5.5	<i>Modified specification of 2.5 mm to 5 mm.</i> <i>Explanation: The specification is widely recognised and accepted by the industry in Singapore.</i>
Clause 6	<i>Added local requirement 'Materials shall have a minimum tensile strength of 380 N/mm²'.</i> <i>Explanation: The minimum tensile strength of 380 N/mm² is widely recognised and accepted by the industry in Singapore.</i>
Annex C – Table C.1	<i>Modified values for the torque.</i> <i>Explanation: The torque values listed in Table C.1 is widely recognised and accepted by the industry in Singapore.</i>
Annex D	<i>Added Annex D as informative reference.</i> <i>Explanation: Annex D lists examples of clamps currently being used in Singapore and aims to provide guidance.</i>

Where appropriate, the words 'British Standard' have been replaced by 'Singapore Standard'.

Attention is drawn to the possibility that some of the elements of this Singapore Standard may be the subject of patent rights. Enterprise Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

1. *Singapore Standards (SSs) and Technical References (TRs) are reviewed periodically to keep abreast of technical changes, technological developments and industry practices. The changes are documented through the issue of either amendments or revisions.*
2. *An SS or TR is voluntary in nature except when it is made mandatory by a regulatory authority. It can also be cited in contracts making its application a business necessity. Users are advised to assess and determine whether the SS or TR is suitable for their intended use or purpose. If required, they should refer to the relevant professionals or experts for advice on the use of the document. Enterprise Singapore shall not be liable for any damages whether directly or indirectly suffered by anyone or any organisation as a result of the use of any SS or TR.*
3. *Compliance with a SS or TR does not exempt users from any legal obligations.*

Specification for earthing and bonding clamps

1 Scope

This Singapore Standard specifies performance and mechanical requirements for clamps used to provide mechanically and electrically sound means of earthing and/or bonding, which are primarily intended for use in electrical installations for the connection of:

- a) earthing conductors, having a cross-sectional area in the range 2.5 mm^2 to 70 mm^2 , to earth electrode rods or other means of earthing;
- b) bonding conductors to metal tubes of circular cross-section that have circumferences of not less than 18.8 mm (i.e. diameters of not less than 6 mm).

NOTE 1 – These clamps are also suitable for electrically bonding other conductive parts, where at least one is a tube of circular cross-section. Such clamps are not intended for connection to the armour or sheath of a cable.

NOTE 2 – Clamps specified in this standard are intended to be used singly.

NOTE 3 – There is no correlation between the size of the conductor which the clamp conductor can accommodate and the size of tube to which it is intended to be fitted.

2 Normative references

The following referenced documents are indispensable for the application of this standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS EN 1057, *Copper and copper alloys – Seamless, round copper tubes for water and gas in sanitary and heating applications*

BS EN 13601, *Copper and copper alloys – Copper rod, bar and wire for general electrical purposes*