

SINGAPORE STANDARD

Materials and performance tests for aluminium curtain walls

Confirmed 2007



Published by

Enterprise
Singapore

SS 381 : 1996 (2007)
(ICS 91.060.10)

SINGAPORE STANDARD

**Materials and performance tests for aluminium
curtain walls**

All rights reserved. Unless otherwise specified, no part of this Singapore Standard may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from Enterprise Singapore. Request for permission can be sent to: standards@enterprisesg.gov.sg.

ISBN 9971-67-545-5

SS 381 : 1996

This Singapore Standard having been approved by the Building Materials Product Standards Committee was endorsed by the Standards Council on 20 August 1996.

First published, 1996.

The Building Materials Product Standards Committee appointed by the Standards Council consists of the following members:

	Name	Organisation
Chairman	: Mr Kenneth Chen Koon Lap	Standards Council
Deputy Chairman	: Miss Tan Chiew Wan	Singapore Productivity and Standards Board
Secretary	: Mr Han Kin Sew	Singapore Productivity and Standards Board
Members	: Mr Boo Geok Kwang	Singapore Civil Defence Force
	Mr Richard Cheng	Singapore Contractors Association Limited
	Dr Chiew Sing Ping	Nanyang Technological University
	Er Goh Soo Meng	Institution of Engineers, Singapore
	Mrs Goh-Sim Mui Hiang	Public Works Department
	Mr John Kong Wai Meng	Singapore Confederation of Industries
	Mr Lee Seng Kee	Singapore Mass Rapid Transit
	Mr Arthur Loh	Singapore Institute of Architects
	Mdm Ng Bee Theng	Urban Redevelopment Authority
	Mr Ng Lye Hock	Housing and Development Board
	Mr Ong Geok Soo	Jurong Town Corporation
	A/Prof Tam Chat Tim	National University of Singapore
	Mr Tan Tian Chong	Construction Industry Development Board

The Technical Committee appointed by the Building Materials Product Standards Committee and responsible for the preparation of this standard consists of representatives from the following organisations:

	Name	Organisation
Chairman	: Ms Teresa Chee	Singapore Institute of Architects
Deputy Chairman	: A/Prof Somsak Swadduwudhipong	National University of Singapore
Secretary	: Mr Han Kin Sew	Singapore Productivity and Standards Board
Members	: Mr Douglas Cheam	Singapore Contractors Association Limited
	Er Chen Hao	Institution of Engineers, Singapore
	Mr Philip Kwang Chwee Seng	Singapore Confederation of Industries
	Mr Desmond Lau	Singapore Productivity and Standards Board
	Ms Lim Eng Hon	Singapore Confederation of Industries
	Mr Lim Hon Chee	Association of Consulting Engineers, Singapore
	Mr Low Chin Min	Construction Industry Development Board
	Mr Lum Wing Hung	Housing and Development Board
	Mr Andrea G Maoro	Singapore Confederation of Industries
	Mr Poon Hin Kong	Public Works Department

Members	:	Lta Alroy Tan	Singapore Civil Defence Force
		Mr Tan Teng Hooi	Nanyang Technological University
Co-opted Members	:	Mr Simon Chin Yun Fen	Individual Capacity
		A/Prof Edmund C C Choi	Individual Capacity
		Mr Chua Teck Huat	Individual Capacity
		Mr Enrique Klien	Individual Capacity

CONTENTS

	Page
Foreword - - - - -	5
1. Scope - - - - -	6
2. Definitions - - - - -	6
3. Materials - - - - -	7
4. Test specimen - - - - -	8
5. Performance - - - - -	9
6. Report - - - - -	11
7. Re-testing - - - - -	12

APPENDICES

A Air permeability test - - - - -	15
B Watertightness test - - - - -	17
C Structural performance test - - - - -	19
D Proof load test - - - - -	21
E Recommended periods for calibration - - - - -	22

FIGURES

1. Air permeability limits for curtain walls with fixed or opening lights -	10
2a. General arrangement of a typical test chamber (Exterior of test specimen facing inward of chamber) - - - - -	13
2b. General arrangement of a typical test chamber (Exterior of test specimen facing outward of chamber) - - - - -	14
3. Pressure sequence for watertightness test - - - - -	18

SINGAPORE STANDARD

MATERIALS AND PERFORMANCE TESTS FOR ALUMINIUM CURTAIN WALLS

FOREWORD

This Singapore Standards was prepared by the Technical Committee for Curtain Walls under the direction of the Building Materials Product Standards Committee.

This standard stipulates the technical requirements for the essential materials and evaluation methods for checking the structural adequacy of aluminium curtain walls and their ability to resist water penetration and air leakage.

The performance of the curtain wall systems as an effective barrier against water penetration, air leakage and its structural integrity is dependent upon the technical design and engineering and detailing of the curtain wall system. The objective of the performance evaluation in the laboratory is to check the compliance of the system against the design, and in the course of doing that weakness, if any, in the design may be revealed. In obtaining a good aluminium curtain wall, proper installation is just as important as intelligent design and good fabrication.

The specification for infill panels are not laid down in this standard in view of the diverse variety of available materials.

In preparing this specification, reference was made to the following publications:

1. ASTM E 283 - 91 : Standard test method for determining the rate of air leakage through exterior windows, curtain walls, and doors under specified pressure differences across the specimen
2. ASTM E 330 - 90 : Standard test method for structural performance of exterior windows, curtain walls, and doors by uniform static air pressure difference
3. ASTM E 331 --86 : Standard test method for water penetration of exterior windows, curtain walls, and doors by uniform static air pressure difference
4. SS 212 :1988 : Specification for aluminium alloy windows
5. Standard and guide to good practice for curtain walling by Centre for Windows and Cladding Technology University of Bath, UK

Acknowledgement is made for the use of information from the above publications.

Attention is drawn to the possibility that some of the elements of this Technical Reference may be the subject of patent rights. Enterprise Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

1. *Singapore Standards (SSs) and Technical References (TRs) are reviewed periodically to keep abreast of technical changes, technological developments and industry practices. The changes are documented through the issue of either amendments or revisions.*
2. *An SS or TR is voluntary in nature except when it is made mandatory by a regulatory authority. It can also be cited in contracts making its application a business necessity. Users are advised to assess and determine whether the SS or TR is suitable for their intended use or purpose. If required, they should refer to the relevant professionals or experts for advice on the use of the document. Enterprise Singapore shall not be liable for any damages whether directly or indirectly suffered by anyone or any organisation as a result of the use of any SS or TR.*
3. *Compliance with a SS or TR does not exempt users from any legal obligations*

1. SCOPE

This Singapore Standard specifies materials and performance standards for aluminium curtain walls. The performance standard includes only tests for air permeability, watertightness and structural performance.

This standard may involve hazardous materials, operations, and equipment. This standard does not intend to address all of the safety problems associated with their use. It is the responsibility of whoever uses this standard to consult and establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. DEFINITIONS

2.1 Curtain Wall. It is a wall acting as a primary barrier to protect the building interior against air infiltration, water penetration, wind and sound.

2.2 Sealant. An elastomeric material with adhesive qualities that joins components of a similar or dissimilar nature to provide an effective barrier against the passage of air and water.

2.3 Specifying Authority. Architect, designer, engineer, contracting officer who has the authority to amend and/or approve any change to the design.

2.4 Design Wind Pressure. Wind pressure for the design of curtain wall. The pressure shall be determined in accordance with BS CP 3 : Chapter V : Part 2 or other wind design code acceptable to the authority or by boundary layer wind tunnel tests.

2.5 Air Permeability. The property of a closed test specimen to let air pass when it is subject to a differential pressure. The air permeability is characterized by a flow of air expressed in m^3/h as a function of the pressure. This flow may be related to the opening surface area of the test specimen (flow per unit of surface $m^3/h/m^2$), or to the length of opening joint (flow per unit of length $m^3/h/m$), or to the total surface area of the test specimen (flow per unit of surface $m^3/h/m^2$).

2.6 Pressure Difference (Pa). The specified differential static air pressure across the specimen. The difference is positive when the external pressure is higher than the internal pressure. It is negative when the external pressure is lower than the internal pressure.

2.7 Opening Light. Any part of the test specimen that can be moved within the main frame. By convention, the surface of the opening light is equal to the apparent surface, seen from inside. The length of the joints is obtained from the same dimensions as those used for calculation of the surface area.

2.8 Fixed Light. Any part of the test specimen that is fixed in position.

2.9 Test Load. The design wind pressure (unless otherwise specified) both positive and negative for which the specimens to be tested, expressed in Pascals.

2.10 Permanent Deformation. The permanent displacement from an original position that remains after an applied load has been removed.