

SINGAPORE STANDARD

Specification for steel surface cable trunking and accessories

Incorporating Amendment No. 1
Confirmed 2012



Published by

Enterprise
Singapore

SS 249 : 1981 (2012)
(ICS 29.100.10)

SINGAPORE STANDARD

Specification for steel surface cable trunking and accessories

All rights reserved. Unless otherwise specified, no part of this Singapore Standard may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from Enterprise Singapore. Request for permission can be sent to: standards@enterprisesg.gov.sg.

ISBN 9971-67-035-6

SS 249 : 1981 (2012)

This Singapore Standard having been approved by the Electrical Engineering Industry Standards Committee was endorsed by the Standards Council on 20 March 1981.

First published, 1981.

The Electrical Engineering Industry Standards Committee appointed by the Standards Council consists of the following members:

	Name	Organizations
Chairman	: Mr Ng Nam Wah	<i>Standards Council</i>
Secretary	: Mr Tan Hsuan Heng	<i>Singapore Institute of Standards and Industrial Research</i>
Members	: Mr Choy Fook Kee	<i>Telecommunication Authority of Singapore</i>
	Mr Fook Kong Deen	<i>Singapore Electrical Trades Association</i>
	Mr Kaan Quan Hang	<i>Electrical Branch, Public Works Department</i>
	Mr N Karthigayan	<i>Institution of Engineers, Singapore</i>
	Assoc Prof Kooi Pang Shyan	<i>Electrical Engineering Department, National University of Singapore</i>
	Mr Lee Khet Pow	<i>Singapore Manufacturers' Association</i>
	Mr Lim Chan Tai	<i>Housing and Development Board</i>
	Mr Raymond Lo	<i>Singapore Institute of Standards and Industrial Research</i>
	Mr P J A Page	<i>Association of Consulting Engineers, Singapore</i>
	Mr Tan Boon Kee	<i>Electricity Department, Public Utilities Board</i>
	Mr Tan Sing Ong	<i>Jurong Town Corporation</i>

The Technical Committee appointed by the Electrical Engineering Industry Standards Committee and responsible for the preparation of this standard, consists of representatives from the following organizations :

	Name	Organizations
Chairman	: Mr Tan Beng Watt	<i>Institution of Engineers, Singapore</i>
Secretary	: Mr Phua Kim Chua	<i>Singapore Institute of Standards and Industrial Research</i>
Members	: Mrs Philip Adams	<i>Singapore Institute of Standards and Industrial Research</i>
	Mr Eio Siak Peng	<i>Housing and Development Board</i>
	Mr Foo Kong Deen	<i>Singapore Electrical Trades Association</i>
	Mr Ng Chew Wai	<i>Jurong Town Corporation</i>
	Dr S K Roy	<i>National University of Singapore</i>
	Mr Shen Sin Fon	<i>Public Utilities Board</i>
	Mr Tay Siew Choon	<i>Singapore Manufacturers' Association</i>

To keep abreast of technological changes and new technical developments in the manufacturing sector, Singapore Standards are subject to periodical review. Revisions of Singapore Standards are announced through the issue either of amendment slips or of revised editions.

Contents

	Page
Foreword _____	4

SPECIFICATION

1	Scope _____	5
2	Definitions _____	5
3	General requirements _____	5
4	General conditions for tests _____	5
5	Classification _____	6
6	Marking _____	6
7	Details of construction _____	7
8	Dimensions _____	7
9	Resistance to corrosion _____	8
10	Electrical continuity test _____	9
11	Resistance to scratches _____	9
12	Paint thickness _____	9
13	Coating weight _____	9

APPENDICES

A	Tests _____	10
B	Some preferred designs for accessories _____	11

Foreword

This specification was drawn up by the Technical Committee for Steel Surface Cable Trunking and Accessories under the authority of the Electrical Engineering Industry Standards Committee.

Due to the large number of different trunking systems currently being manufactured, it has not been possible to standardize details of all the ancillary fittings in general use. The standard, therefore, is limited to the standardization of overall dimensions and to the classification of steel trunking according to the type of protective finish against corrosion.

In preparing this specification, reference was made to SS 5 : 1970 'Methods of test for paints, varnishes and related materials'. Acknowledgement is made for the use of information from BS 4678 : Part 1 : 1971 'Steel surface trunking'.

Attention is drawn to the possibility that some of the elements of this Singapore Standard may be the subject of patent rights. Enterprise Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

- 1. Singapore Standards (SSs) and Technical References (TRs) are reviewed periodically to keep abreast of technical changes, technological developments and industry practices. The changes are documented through the issue of either amendments or revisions.*
- 2. An SS or TR is voluntary in nature except when it is made mandatory by a regulatory authority. It can also be cited in contracts making its application a business necessity. Users are advised to assess and determine whether the SS or TR is suitable for their intended use or purpose. If required, they should refer to the relevant professionals or experts for advice on the use of the document. Enterprise Singapore shall not be liable for any damages whether directly or indirectly suffered by anyone or any organisation as a result of the use of any SS or TR.*
- 3. Compliance with a SS or TR does not exempt users from any legal obligations.*

Specification for steel surface cable trunking and accessories

1 Scope

1.1 This Singapore Standard specifies requirements for steel surface cable trunking, associated steel connectors and steel accessories, intended for the protection of cables in electrical installations.

1.2 The specification includes surface trunking having nominal sizes as shown in Table 1. It however does not relate to bench, flushfloor, overhead lighting, skirting or underfloor (duct) trunking.