

SINGAPORE STANDARD

Fans – Efficiency classification for fans



Published by

Enterprise
Singapore

SS ISO 12759 : 2017
ISO 12759:2010, IDT
(ICS 23.120)

SINGAPORE STANDARD

Fans – Efficiency classification for fans

All rights reserved. Unless otherwise specified, no part of this Singapore Standard may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from Enterprise Singapore. Request for permission can be sent to: standards@enterprisesg.gov.sg.

© ISO 2010 – All rights reserved
© Enterprise Singapore 2017

ISBN 978-981-47-8445-0

SS ISO 12759 : 2017

This Singapore Standard was approved by the Energy Standards Committee on behalf of the Singapore Standards Council on 12 October 2017.

First published, 2018

The Energy Standards Committee, appointed by the Standards Council, consists of the following members:

	Name	Capacity
Chairman	: Mr Ho Hiang Kwee	<i>Individual Capacity</i>
1st Dy Chairman	: Mr Ram Bhaskar	<i>National Environment Agency</i>
2nd Dy Chairman	: Mr Wong Kum Hoong	<i>Energy Market Authority</i>
Secretary 1	: Mr Jason Low	<i>SPRING Singapore</i>
Secretary 2	Ms Barbara Bok	<i>SPRING Singapore</i>
Members	: Assoc Prof Chai Kah Hin	<i>National University of Singapore</i>
	Mr Adrian Cheong Wah Onn	<i>Land Transport Authority</i>
	Capt Charles Alexandra De Souza	<i>Maritime and Port Authority of Singapore</i>
	Mr Huang Xuebo	<i>Agency for Science, Technology and Research</i>
	Ms Kavita Gandhi	<i>Sustainable Energy Association of Singapore</i>
	Ms Kriti Gupta	<i>SP PowerGrid Ltd</i>
	Mr Richard Kwok	<i>Singapore Business Federation</i>
	Mr Nilesh Jadhav	<i>Nanyang Technological University</i>
	Mr Tan Chek Sim	<i>Housing & Development Board</i>
	Mr Tan Pua Yong	<i>Singapore Manufacturing Federation</i>
	Er. Teo Kong Poon	<i>The Institution of Engineers, Singapore</i>
	Mr Toh Eng Shyan	<i>Building and Construction Authority</i>
	Prof Tseng King Jet	<i>Singapore Green Building Council</i>
	Mr Wong Toon Suan	<i>Gas Association of Singapore</i>
	Prof Wong Yew Wah	<i>ASHRAE Singapore Chapter</i>
	Er. Yeow Mei Leng	<i>Association of Consulting Engineers Singapore</i>
Co-opted Members	: Mr Norman Lee	<i>Individual Capacity</i>
	Prof Toh Kok Chuan	<i>Individual Capacity</i>

The Working Group, appointed by the Energy Standards Committee to assist in the preparation of this standard, comprises the following experts who contributed in their *individual capacity*:

	Name
Convenor	: Mr Roland Tan
Members	: Assoc Prof Ang Hock Eng Mr Clarence Chiang Mr Chng Tuan Meng Er. Eddie Chong Chun Sen Mr Choong Chow Neng Mr Carsten Ederer Ms Lydia Goh Mr David Lau Mr Norman Lee Ms Tracy Liu Mr Colin Ong Er. Ong Eng Tong Mr Kelvin Ong Mr S Suresh Kumar Mr Toh Eng Shyan Dr Tseng King Jet Mr Xu Xiao Ming

The organisations in which the experts are involved are:

ABB Pte Ltd
Association of Consulting Engineers Singapore
Building and Construction Authority
Chevron Philips Chemicals Asia Pte Ltd
ebm-papst SEA Pte. Ltd.
EV Solutions Pte Ltd
G-Energy Global Pte Ltd
Kruger Engineering Pte Ltd
MSD International GmbH (Singapore Branch)
National Environment Agency
Nanyang Technological University
Schneider Electric Singapore Pte Ltd
Singapore Green Building Council
Singapore Manufacturing Federation
Sustainable Energy Association of Singapore
The Institution of Engineers, Singapore

(blank page)

Contents

	Page
National Foreword.....	6
Foreword	7
Introduction	8
1 Scope.....	9
2 Normative references	9
3 Terms and definitions.....	9
3.1 Fans — General.....	10
3.2 Fan or test installation categories according to the arrangement of ducting.....	11
3.3 Fans — Definitions relating to calculations	11
3.4 Definitions relating to fan efficiency	13
3.5 Fan efficiency grades	14
4 Symbols and units	14
5 Fan installation, efficiency and tolerance.....	16
5.1 General.....	16
5.2 Use of installation categories	17
5.3 Calculation of efficiency.....	18
5.4 Tolerances	18
6 Ratings	19
6.1 General.....	19
6.2 Bare shaft fans	19
6.3 Driven fans.....	22
Annex A (normative) Energy efficiency grades for bare shaft fans	29
Annex B (normative) Calculation method to determine efficiency of component parts	30
Annex C (informative) Variation of fan performance between installation categories.....	35
Annex D (informative) Input power calculation for driven fans at design point	36
Annex E (informative) Selection of fans for best efficiency	44
Annex F (informative) Determination of efficiency grade for a driven fan	47
Annex G (informative) Explanatory note	50
Bibliography	52

National Foreword

This Singapore Standard was prepared by a Working Group under the direction of the Energy Standards Committee.

This standard is identical with ISO 12759:2010 published by the International Organization for Standardization.

Attention is drawn to the following:

1. Where appropriate, the words "International Standard" shall be read as "Singapore Standard".
2. The reference to "IEC/TS 60034-31" shall be replaced by "TR IEC/TS 60034-31".
3. The comma has been used throughout as a decimal marker whereas in Singapore Standards it is a practice to use a full point on the baseline as the decimal maker.

Attention is drawn to the possibility that some of the elements of this Singapore Standard may be the subject of patent rights. Enterprise Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

1. *Singapore Standards (SSs) and Technical References (TRs) are reviewed periodically to keep abreast of technical changes, technological developments and industry practices. The changes are documented through the issue of either amendments or revisions.*
2. *An SS or TR is voluntary in nature except when it is made mandatory by a regulatory authority. It can also be cited in contracts making its application a business necessity. Users are advised to assess and determine whether the SS or TR is suitable for their intended use or purpose. If required, they should refer to the relevant professionals or experts for advice on the use of the document. Enterprise Singapore shall not be liable for any damages whether directly or indirectly suffered by anyone or any organisation as a result of the use of any SS or TR.*
3. *Compliance with a SS or TR does not exempt users from any legal obligations.*

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 12759 was prepared by Technical Committee ISO/TC 117, *Fans*.

Introduction

The last decade has seen not only an escalation in the price, but also an increasing recognition of the finite life of many of the fossil fuels in use. There is also a belief that climatic change is due to an increase in the levels of carbon dioxide in the atmosphere. This has led to many nations reviewing methods of energy generation and usage.

Therefore, there is a need to promote energy efficiency in order to maintain economic growth. This requires better selection of equipment by users and better design of this equipment by manufacturers.

Fans of all types are used for ventilation and air conditioning, process engineering (drying, pneumatic conveying), combustion air supply and agriculture, etc. Indeed, the energy usage by fans has been calculated as nearly 20 % of worldwide demand.

The fan industry is of a global nature, with a considerable degree of exporting and licensing. To ensure that defined fan performance characteristics are common throughout the world, a series of International Standards has been developed. It is the belief of the industry that there is a need for the recognition of minimum efficiency standards. To encourage their implementation, a classification system is proposed which incorporates a series of efficiency bands. With improvements in technology and manufacturing processes, the minimum efficiency levels can be reviewed and increased over time.

This International Standard can be used by legislators or regulatory bodies for defining future energy saving targets.

Fans — Efficiency classification for fans

1 Scope

This International Standard establishes a classification of fan efficiency for all fan types driven by motors with an electrical input power range from 0,125 kW to 500 kW. This International Standard is applicable to bare shaft and driven fans, as well as fans integrated into products. Fans integrated into products are measured as stand-alone fans.

This International Standard is not applicable to:

- a) fans for smoke and emergency smoke extraction;
- b) fans for industrial processes;
- c) fans for automotive application, trains and planes;
- d) fans for potentially explosive atmospheres;
- e) box fans, powered roof ventilators and air curtains;
- f) jet fans for use in car parks and tunnel ventilation.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5801:2007, *Industrial fans — Performance testing using standardized airways*

ISO 13348:2007, *Industrial fans — Tolerances, methods of conversion and technical data presentation*

ISO 13349:2010, *Fans — Vocabulary and definitions of categories*

IEC 60034-2-1, *Rotating electrical machines — Part 2-1: Standard methods for determining losses and efficiency from tests (excluding machines for traction vehicles)*

IEC 60034-30, *Rotating electrical machines — Part 30: Efficiency classes of single-speed, three-phase, cage-induction motors*