

TR 56 : Part 3 : 2020

(ICS 01.140.30; 47.020; 47.040)

TECHNICAL REFERENCE

LNG bunkering

– Part 3 : Procedures and safety distances



TR 56 : Part 3 : 2020

(ICS 01.140.30; 47.020; 47.040)

TECHNICAL REFERENCE

LNG bunkering

– Part 3 : Procedures and safety distances

Published by Enterprise Singapore

All rights reserved. Unless otherwise specified, no part of this Technical Reference may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from Enterprise Singapore. Request for permission can be sent to: standards@enterprisesg.gov.sg.

© Enterprise Singapore 2020

ISBN 978-981-48-9487-6

The content of this Technical Reference was approved on 31 March 2020 by the Chemicals Standards Committee (CSC) under the purview of the Singapore Standards Council.

First published, 2017

First revision, 2020

CSC consists of the following members:

	Name	Representation
Chairman	: Dr Keith Carpenter	<i>Individual Capacity</i>
Deputy Chairman	: Er. Lucas Ng	<i>Individual Capacity</i>
Secretary	: Ms Elane Ng	<i>Standards Development Organisation @ Singapore Chemical Industry Council</i>
	Ms Rosmalinda Tay	<i>Standards Development Organisation @ Singapore Chemical Industry Council</i>
Members	: Mr Goh Tiak Boon	<i>Individual Capacity</i>
	Prof Alfred Huan	<i>Individual Capacity</i>
	Er. Khong Beng Wee	<i>Individual Capacity</i>
	Mr Terence Koh	<i>Singapore Chemical Industry Council Limited</i>
	Dr Leong Kwai Yin	<i>Individual Capacity</i>
	Dr Thomas Liew	<i>National Metrology Centre</i>
	Mr Lim Eng Kiat	<i>Individual Capacity</i>
	Mdm Jaime Lim	<i>Ministry of Manpower</i>
	Mr Lim Kian Chye / Mr Ng Eng Fu	<i>Housing & Development Board</i>
	Prof Loh Kian Ping	<i>National University of Singapore</i>
	Dr Loh Wah Sing	<i>Individual Capacity</i>
	Ms Pamela Phua	<i>Singapore Paint Industry Association</i>
	Mr Seah Khen Hee	<i>Individual Capacity</i>
	A/Prof Timothy Tan	<i>Nanyang Technological University</i>
	Dr Teo Tang Lin	<i>Chemical Metrology Division, Health Sciences Authority</i>
	Mr Yao Yikai	<i>Maritime and Port Authority of Singapore</i>
	Ms Suzanna Yap	<i>National Environment Agency</i>
Co-opted Members	: Ms Christina Loh	<i>Individual Capacity</i>
	Mr Pitt Kwan Wah	<i>Individual Capacity</i>

CSC set up the Technical Committee on LNG Bunkering to oversee the preparation of this standard. The Technical Committee consists of the following members:

	Name	Representation
Chairman	: Mr Goh Tiak Boon	<i>Individual Capacity</i>
Secretary	: Ms Elane Ng	<i>Standards Development Organisation @ Singapore Chemical Industry Council</i>
Members	: Dr Khorshed Alam	<i>Singapore Shipping Association</i>
	Dr Giulio Gennaro / Mr Foo Nan Cho	<i>Society of Naval Architects and Marine Engineers Singapore</i>
	Dr Lim Ee Meng	<i>National Metrology Centre</i>
	Mr Sandeep Mahawar	<i>Singapore LNG Corporation Pte Ltd</i>
	Mr Varun Iyer Mani	<i>Maersk Line</i>
	LTC Ng Geok Meng	<i>Singapore Civil Defence Force</i>
	Mr Cristian Popescu	<i>CMA CGM</i>
	Mr Saunak Rai	<i>FueLNG Pte Ltd</i>
	Capt Say Eng Sin	<i>Singapore Nautical Institute</i>
	Mr Soh Zi Quan	<i>Ministry of Manpower</i>
	Mr Richard Tan	<i>Pavilion Energy Singapore Pte Ltd</i>
	Mr Alex Tang	<i>The International Bunker Industry Association</i>
	Capt Satinder Singh Viridi	<i>Singapore Maritime Academy</i>
	Mr Yao Yikai	<i>Maritime and Port Authority of Singapore</i>
	Mr Zheng Huijian	<i>Energy Market Authority</i>

The Technical Committee set up the Working Group on LNG Bunkering Procedures and Safety Distances to prepare this standard. The Working Group consists of the following experts who contribute in their *individual capacity*:

	Name
Co-Convenors	: Mr Julien Boulland Ms Shanice Koh
Members	: Capt. Andy Chew Kian Kwee Mr Aw Teck Leong Ms Marion During Ms Ina Foo Mr Gan Shaowei Mr Jeremy Lee Mr Rajesh Mahesan Mr Stephane Maillard Mr Subhendu Mukherjee Capt Tomoyoshi Nasuno LTA Shavithiya Shanmugam Mr Siah Poh Chiang

Members : Capt. Anthony Sim
Mr So Kah Meng
Mr Yang Zhan Ming

The organisations in which the experts of the Working Group are involved are:

Bureau Veritas Marine (Singapore) Pte Ltd
China Classification Society
FueLNG Pte Ltd
Gas Technology Development Pte Ltd
Gaztransport & Technigaz (GTT)
Jurong Port Singapore
Keppel Smit Towage Pte Ltd
Lloyd's Register Singapore Pte Ltd
Maritime and Port Authority of Singapore
Mitsui O.S.K. Lines
Pavilion Energy Singapore Pte Ltd
PSA Marine (Pte) Ltd
Shell International Eastern Trading Co
Sinanju Marine Services Pte Ltd
Singapore Civil Defence Force
Total Marine Fuels Singapore

Contents

	Page
Foreword _____	6
0 Introduction _____	8
1 Scope _____	8
2 Normative references _____	8
3 Terms and definitions _____	8
4 Properties of LNG _____	8
5 Safety requirements _____	9
6 Bunkering procedure _____	14
7 Simultaneous operations _____	18
8 Cassette bunkering _____	19
9 Shore-to-ship bunkering _____	19

Annexes

A LNG bunkering checklists (informative) _____	20
B RACI matrix for bunkering stakeholders (informative) _____	35
C Examples of hand signals for bunkering communication (informative) _____	36
D Determination of controlled zones (informative) _____	37
E Emergency scenarios (informative) _____	42
F Examples of SIMOPS (informative) _____	44

Tables

A.1 Representatives for LNG transfer modes _____	20
D.1 Examples of risk acceptance criteria _____	41

Figures

D.1 Example of hazardous area, safety zone and monitoring zone for truck-to-ship LNG bunkering _____	37
D.2 Example of hazardous area, safety zone and monitoring zone for ship-to-ship LNG bunkering _____	38
D.3 Distance to LFL as a function of the release volume _____	39
D.4 Distance to LFL as a function of the system pressure (25 mm hole) _____	40
Bibliography _____	45

Foreword

This Technical Reference was prepared by the Working Group on LNG bunkering procedures and safety distances set up by the Technical Committee on LNG bunkering under the purview of CSC.

TR 56 consists of the following parts under the generic title “LNG bunkering”:

- Part 1 : General introduction
- Part 2 : Requirements for custody transfer
- Part 3 : Procedures and safety distances
- Part 4 : Competency requirements for personnel

In this revision, the following changes were made:

- Enhancement of SIMOPS requirements under Clause 7 and SIMOPS examples listed in new Annex F;
- Inclusion of responsibility matrix for bunkering stakeholders in new Annex B;
- Better clarity on controlled zones under Clause 5.6;
- Amendments to LNG bunkering checklists with experience gained from truck-to-ship mode.

In preparing this TR, reference was made to the following documents:

1. BV Guidelines on LNG Bunkering (NI 618 – July 2014)
2. DNVGL-RP-G105 Development and operation of liquefied natural gas bunkering facilities (2015)
3. IAPH LNG bunker checklists (2019)
4. ISO 17776 : 2000 – Petroleum and natural gas industries – Offshore production installations – Guidelines on tools and techniques for hazard identification and risk assessment
5. ISO 31010 : 2009 – Risk Management - Risk assessment techniques
6. ISO/TS 16901 : 2015 – Guidance on performing risk assessment in the design of onshore LNG installations including the ship/shore interface
7. ISO/TS 18683 : 2015 - Guidelines for systems and installations for supply of LNG as fuel to ships
8. OCIMF Mooring equipment guidelines, 4th edition 2018, MEG4
9. SGMF LNG Bunkering Safety Guidelines (2015)
10. SIGTTO ESD Arrangements & Linked Ship/Shore Systems for Liquefied Gas Carriers (2009)
11. SIGTTO LNG Transfer Arms and Manifold Draining, Purging and Disconnection Procedure (2012)

Annex B of ISO 20519 was adapted and Table D.1 of ISO/TS 18683 was reproduced in Annex D of this TR, and the IAPH LNG bunker checklists were adapted as Annex A of this TR with the permission of the International Organization for Standardization and the International Association of Ports and Harbors respectively.

Acknowledgement is made for the use of information from the following publications.

Acknowledgement is also made to The Society for Gas as a Marine Fuel (SGMF) for their kind assistance in the development of this Technical Reference and for their permission to reproduce/adapt the works from the following SGMF Guidelines:

- SGMF Quality and Quantity – Contractual Guidelines (definitions into TR 56 : Part 1 : 2020 and clause 5.4 into TR 56 : Part 2 : 2020)
- SGMF LNG Bunkering Safety Guidelines (clauses 4.1.1 and 4.2 into TR 56 : Part 3 : 2020)
- SGMF Training and Competency Guidelines (definitions into TR 56 : Part 1 : 2020 and clauses 4.1 to 4.8 and clause 5 into TR 56 : Part 4 : 2020)
- SGMF Recommendation of Controlled Zones during LNG Bunkering (clause 4 controlled zones definitions into TR 56 : Part 1 : 2020)

The above Guidelines are copyright of SGMF (further information is available from <http://www.sgmf.info/>). SGMF accepts no responsibility for the placement and context in which the extracts and contents are reproduced or interpreted by ESG or by any end user of either of these Guidelines. SGMF is also in no way responsible for any other content or accuracy in this TR and shall not be liable for any damages whether directly or indirectly suffered by anyone as a result of reliance on this TR.

This TR is a provisional standard made available for application over a period of three years. The aim is to use the experience gained to update the TR so that it can be adopted as a Singapore Standard. Users of the TR are invited to provide feedback on its technical content, clarity and ease of use. Feedback can be submitted using the form provided in the TR. At the end of the three years, the TR will be reviewed, taking into account any feedback or other considerations, to further its development into a Singapore Standard if found suitable.

This TR is expected to be used by all stakeholders involved in the LNG bunker supply chain including LNG bunker suppliers, bunker tanker owners / operators, LNG fuel receiving vessels, ship owners / operators, training institutions, third-party agencies and relevant authorities.

Attention is drawn to the possibility that some of the elements of this TR may be the subject of patent rights. Enterprise Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

1. *Singapore Standards (SSs) and Technical References (TRs) are reviewed periodically to keep abreast of technical changes, technological developments and industry practices. The changes are documented through the issue of either amendments or revisions. Where SSs are deemed to be stable, i.e. no foreseeable changes in them, they will be classified as "Mature Standards". Mature Standards will not be subject to further review, unless there are requests to review such standards.*
2. *An SS or TR is voluntary in nature except when it is made mandatory by a regulatory authority. It can also be cited in contracts making its application a business necessity. Users are advised to assess and determine whether the SS or TR is suitable for their intended use or purpose. If required, they should refer to the relevant professionals or experts for advice on the use of the document. Enterprise Singapore and the Singapore Standards Council shall not be liable for any damages whether directly or indirectly suffered by anyone or any organisation as a result of the use of any SS or TR. Although care has been taken to draft this standard, users are also advised to ensure that they apply the information after due diligence.*
3. *Compliance with a SS or TR does not exempt users from any legal obligations.*

Technical Reference – LNG bunkering – Part 3 : Procedures and safety distances

0 Introduction

This Technical Reference (TR) was developed for the benefit of the LNG bunker industry in Singapore. This TR is intended to provide guidance to parties involved in LNG bunkering, thereby ensuring that an LNG fuelled vessel can refuel with a high level of safety, integrity and reliability regardless of the type of bunkering facility.

This TR does not alter the contractual obligations of parties involved in the LNG bunker delivery.

Truck-to-ship and ship-to-ship bunkering transfers are expected to be the predominant modes in the near future in Singapore and as such, this edition pays more attention to these modes of transfers. However, refer to Clause 8 and Clause 9 below which relate to cassette bunkering and shore-to-ship bunkering respectively. Safety procedures and other requirements via the other transfer modes will be gradually added in subsequent editions when such modes become more prevalent.

1 Scope

This TR covers the principles, requirements and procedures for LNG bunkering operations (shore-to-ship, truck-to-ship, ship-to-ship and cassette bunkering) in Singapore. Recommendations for procedures, responsibilities and equipment required are provided in this TR.

2 Normative references

The following referenced documents are indispensable for the application of this TR. The latest edition of the referenced document (including any amendments) applies.

IEC 60079-10-1	Explosive atmospheres – Part 10-1: Classification of areas – Explosive gas atmospheres
ISO 20519	Specification for bunkering of liquefied natural gas fueled vessels
ISO 21593	Technical requirements for dry-disconnect/connect couplings for bunkering liquefied natural gas