

Code of practice for fire hydrant, rising mains and hose reel systems

AMENDMENT NO. 1

October 2021

1. Page 18, 2.2.3.5

Replace clause 2.2.3.5 with:

No other services shall be housed within the protected shaft unless it is for fire fighting (which includes cabling/wiring with extra low voltage serving fire protection systems).