

SS 241:2024
BS 5733:2010+A1:2014, MOD
(ICS 29.120.01)

SINGAPORE STANDARD

**Specification for general requirements
for electrical accessories**

SS 241:2024

BS 5733:2010+A1:2014, MOD
(ICS 29.120.01)

SINGAPORE STANDARD

Specification for general requirements for electrical accessories

Published by Enterprise Singapore

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilised in any form or by any means, electronic or mechanical, including photocopying and microfilming, without permission in writing from Enterprise Singapore. Request for permission can be sent to: standards@enterprisesg.gov.sg.

© Enterprise Singapore 2024

ISBN 978-981-5237-67-2

Contents

	Page
National Foreword _____	5
1 Scope _____	6
2 Normative references _____	7
3 Terms and definitions _____	8
4 Classification _____	17
5 General requirements _____	17
6 Type testing _____	17
7 Rating _____	18
8 Marking _____	18
9 Dimensions _____	21
10 Clearances, creepage distances and solid insulation _____	21
11 Accessibility of live parts _____	25
12 Provision for earthing _____	28
13 Construction _____	29
14 Terminals and terminations _____	33
15 Screws, current-carrying parts and connections _____	44
16 Provisions for cables and cords _____	46
17 Resistance to ageing _____	50
18 Resistance to harmful ingress of water and resistance to humidity _____	50
19 Insulation resistance and electric strength _____	51
20 Temperature rise _____	52
21 Mechanical strength _____	55
22 Resistance to heat _____	64
23 Resistance of insulating material to abnormal heat, and to fire _____	67
24 Clause deleted _____	68
25 Resistance to excessive residual stresses and to rusting _____	68

Annexes

A (informative) Summary of tests on insulating parts of accessories _____	69
B (normative) Measurement of clearances and creepage distances _____	70
C (normative) Determination of the comparative tracking index (CTI) and proof tracking index (PTI) _____	75
D (normative) Relation between rated impulse withstand voltage, rated voltage and overvoltage category _____	76
E (normative) Pollution degree _____	77
F (normative) Impulse withstand voltage test _____	78

Bibliography _____	80
--------------------	----

Figures

1	Examples of pillar terminals _____	13
2	Examples of screw terminals and stud terminals _____	14
3	Examples of saddle terminals _____	15
4	Examples of lug terminals _____	15
5	Examples of a mantle terminal _____	16
6	Thread forming tapping screw _____	16
7	Thread cutting tapping screw _____	16
8	Gauge for checking non-accessibility through shutters _____	26
9	Apparatus for testing accessory enclosure fixing screws _____	27
10	Solid link for test on fuseclips _____	31
11	Arrangement for checking damage to conductors _____	35
11A	Arrangement for voltage drop test [New Figure] _____	44
12	Apparatus for flexing test _____	49
13	General view of an example of impact test apparatus _____	57
14	Constructional details of striking element _____	58
15	Constructional details of mounting support for test samples _____	59
16	Arrangement for mechanical strength test for portable accessories other than plugs or adaptors _____	60
17	Tumbling barrel _____	61
18	Figure deleted _____	65
19	Apparatus for pressure test on portable accessories _____	66
A.1	Diagrammatic representation of the sequence of tests on insulating parts of accessories_	69

Tables

1A	Minimum clearances for basic insulation _____	22
1B	Minimum creepage distances for basic insulation _____	24
1C	Withstand test voltages for solid insulation types _____	25
2	Conductors to be accommodated by terminals _____	34
3	Torque values for test of screws and nuts _____	35
4	Pull for terminal clamping test _____	36
5	Current for electrical and thermal stress test _____	41
6	Pull and torque tests for flexible cord and cable anchorages _____	47
6A	Cross-sectional areas for copper conductors for temperature-rise test _____	53
7	Multiplying factor for the temperature rise test _____	54
8	Torque for mechanical test on glands _____	64
B.1	Minimum values of width "X" _____	70
D.1	Rated impulse withstand voltage for accessories energized directly from	

	the low voltage mains _____	76
F.1	Test voltages for impulse withstand test _____	79

National Foreword

This Singapore Standard was prepared by the Working Group on Plugs, Socket-outlets and Switches set up by the Technical Committee on Electrical and Electronic Products under the purview of the Electrical and Electronic Standards Committee.

This standard is a revision of SS 241:1996(2008), "Specification for general requirements for electrical accessories". The revised standard is a modified adoption of BS 5733-2010+A1-2014, "General requirements for electrical accessories – Specification" and is implemented with the permission of the British Standards Limited.

The following deviations have been made due to national requirements and the particular needs of the local industry:

1. Changed the ambient temperature under conditions for use for electrical accessories from -5°C to +40°C, the average value over 24 h not exceeding +35°C to having a peak value not exceeding +40°C, the average value over 24 h not exceeding +35°C.
2. Changed the ambient temperature of 20°C ± 5°C used for test condition for 13A fused connection unit to 27°C ± 5°C.
3. Replaced "British Standard" with "Singapore Standard" where applicable.
4. Replaced normative references with Singapore or IEC standards where applicable.

The technical deviations and editorial changes have been added directly to the clauses to which they refer. The technical deviations are marked by a vertical bar on the left margin of the standard.

Attention is drawn to the possibility that some of the elements of this Singapore Standard may be the subject of patent rights. Enterprise Singapore shall not be held responsible for identifying any or all of such patent rights.

NOTE

1. *Singapore Standards (SSs) and Technical References (TRs) are reviewed periodically to keep abreast of technical changes, technological developments and industry practices. The changes are documented through the issue of either amendments or revisions. Where SSs are deemed to be stable, i.e. no foreseeable changes in them, they will be classified as "mature standards". Mature standards will not be subject to further review, unless there are requests to review such standards.*
2. *An SS or TR is voluntary in nature except when it is made mandatory by a regulatory authority. It can also be cited in contracts making its application a business necessity. Users are advised to assess and determine whether the SS or TR is suitable for their intended use or purpose. If required, they should refer to the relevant professionals or experts for advice on the use of the document. Enterprise Singapore and the Singapore Standards Council shall not be liable for any damages whether directly or indirectly suffered by anyone or any organisation as a result of the use of any SS or TR. Although care has been taken to draft this standard, users are also advised to ensure that they apply the information after due diligence.*
3. *Compliance with a SS or TR does not exempt users from any legal obligations.*

Specification for general requirements for electrical accessories

1 Scope

1.1 This Singapore Standard specifies requirements and tests to check the safety in normal use of electrical accessories which are not covered by other specific Singapore Standards.

Such accessories are intended for use in household, commercial and light industrial premises where:

- the nominal supply voltage does not exceed 250 V a.c. single-phase, 50 Hz to 60 Hz or 250 V d.c.;
- the rated current of the accessory does not exceed 63 A.

Unless otherwise stated by the manufacturer, accessories conforming to this standard are intended for connection by cables or flexible cords conforming to SS 358 or IEC 60227 series.

1.2 This standard also covers:

- “plug-in” and other accessories in which electrical accessory components such as plug-pins, socket-contacts, switches, terminals, etc. are incorporated (see 5.1);
- maintenance free accessories (see 3.31).

1.3 Accessories conforming to this standard are suitable for use under the following conditions of service:

- an ambient temperature in the range -5 °C to +40 °C, the average value over 24 h not exceeding 35 °C;

NOTE 1 Under normal conditions of use, the available cooling air is subject to natural atmospheric variations of temperature and hence the peak temperature occurs only occasionally during the hot season, and on those days when it does occur, it does not persist for lengthy periods.

- a situation not subject to direct radiation from the sun or other source of heat likely to raise temperatures above the limits specified above;
- an altitude not exceeding 2 000 m above sea-level;
- an atmosphere not subject to excessive pollution by smoke, chemical fumes, or other abnormal conditions.

NOTE 2 Accessories conforming to this standard may be suitable for use in other conditions, subject to agreement between manufacturer and user. Information given in a manufacturer's catalogue may take the place of such an agreement.

1.4 Requirements for electromagnetic compatibility are not given, as accessories do not in themselves produce extraneous emissions, nor is their functioning affected by external emissions. Therefore no emission or immunity tests are necessary.

It should be noted that accessories containing active electronic components, other than luminous indicating devices, may be susceptible to, or emit, electromagnetic interference.